



भाकृअनुप-राष्ट्रीय उच्च सुरक्षा पशुरोग संस्थान  
ICAR-National Institute of High Security Animal Diseases

(एवियन इन्फ्लूएंजा ओ.आई.ई. संदर्भ प्रयोगशाला)  
(OIE Reference Laboratory for Avian Influenza)  
आनंद नगर, भोपाल - ४६२०२२ (म.प्र.), भारत  
Anand Nagar, Bhopal - 462022 (M.P.), India



EPABX Tel. No. 0755-2757542, 2750647, FAX: 0755-2758842, Website: www.nihsad.nic.in

F. No. 9-62/17-18/NIHSAD (P&S)

Dated: - 28.06.2017

To,

.....  
.....  
.....

Sub: - Purchase of Junction Boxes for Street Light Poles – reg.

Sir,

We intend to purchase the Junction Boxes for street Light Poles as detailed below for our Institute:-

Description	Qty.
Junction Boxes for Street Light Poles with Length 12 Inch, Width – 8 Inch, Depth – 5 Inch, Material – MS and Mild Steel (M.S.) Sheet, Thickness – 1.5 mm	70


You are requested to please send us a **Quotation** of the above mentioned items. Please note that: -

1. Rates are to be quoted on F.O.R. NIHSAD, Bhopal.
2. Warranty is to be offered for reasonable period.
3. Taxes, if any, to be shown separately.
4. E-Payment will be made within 30 days from the date of receiving of goods in satisfactory condition.
5. Date & Time of opening (Tentative):- 27.07.2017
6. Validity of offer: 90 days.
7. Delivery Period: 15 days.

The quotation may be submitted upto 26.07.2017 In a closed envelope duly super scribed.

*specification enclosed*

Yours sincerely,

  
(S.K. GUPTA)  
Sr. Adm. Officer

### Scope of Works

Fabrication of Junction Boxes for Street Light Poles ( for 16 sq mm. Aluminum Cable ) The Box with Hinges and 02 Panel Door Screws (On Top and Base) having Dimensions as below :

#### **Dimensions of Junction Box :**

Length : 12 inches = 300 mm

Width : 08 inches = 200 mm

Depth : 05 inches = 100 mm

Material : Mild Steel ( M. S ) Sheet

Thickness of M.S. Sheet : 1.5 mm

- 1) The Junction Box will have 04 pre projected holes ( for in and out ) below of size 1" inch each for cable glands of size 1" inch each.
- 2) The Box is to be painted with one coat of Primer and two coats of Cream Colour Enamel Paints.
- 3) The Box has to be provided with Bakelite Base having 01 TB of 100 Amp 4 Way (to hold RYB Lugs ,01 Neutral Link) Earth Link is provided both side and 01 Cut- Out Fuse of Porcelain 6 Amp ( Copper Contact Kit - Kat)
- 4) The Box to be provided with 02 clamps support of size (12 inches in diameter) and necessary screws and bolts of size 02 inch each to hold the box on street pole with clamps.

Note : Vendors are advised to visit the institute premises and see already Installed Junction Boxes before Quoting their rates.

