



भाकृअनुप-राष्ट्रीय उच्चसुरक्षापशुरोगसंस्थान  
ICAR-National Institute of High Security Animal Diseases

(एवियनइन्फ्लूएंजाओ.आई.ई. संदर्भप्रयोगशाला)  
(OIE Reference Laboratory for Avian Influenza)  
आनंदनगर, भोपाल- ४६२०२२ (म.प्र.), भारत  
Anand Nagar, Bhopal - 462022 (M.P.), India



EPABX Tel. No. 0755-2757542, 2750647, FAX: 0755-2758842, Website: www.nihsad.nic.in

File No. 9-2/23-24/NIHSAD(P&S)  
GeM Bid No. GEM/2025/B/6318495

**CORRIGENDUM**

Sr. No.	Particulars (Section No., Clause No., Paragraph / Bullet No., Page. No in the tender document )	Existing terms and conditions	Revised terms and conditions
1.	Page no. 5 at Sr. no. 18 (Payment terms )	Whether the monthly bill raised by the OEM authorized distributor /dealers will be accepted or not?	Yes, shall be accepted. However the bill raised by the OEM authorized distributor /dealer shall display the official logo with name of the OEM and name of the authorized distributor/dealer.
2.	Page no. 12 at Sr. no 6 ( Scope of work / service)	The LPG Gas Bank shall be designed as per the specifications of IS 6044-1/OISD-6044/PESO/GAS CYLINDER RULE-2018 with latest amendment and statutory requirement. The installation should have "Advance Gas Management System" facility with Auto changeover and Leak detection.	Design and installation of LPG gas bank facility and the associated piping and equipments shall be as per the specifications of IS 6044-1/OISD-6044/PESO/GAS CYLINDER RULE-2018 with latest amendment and statutory requirement. The installation shall have "Advance Gas Management System" facility with Auto changeover and gas Leak detection. The LPG gas facility installation shall be certified by the designated officer of the OEM.
3.	Page no. 14 at Sr. no. 6.6 (Operation & Maintenance	The complete operation, maintenance, safety and security of Gas Bank will be in the scope of firm and required manpower to ensure smooth operation and maintenance on 24x7 basis shall be ensured by the firm	The complete maintenance, safety, and security of Gas Bank will be in the scope of firm along with the manpower required to attend for any emergency situations, gas leaks, or any breakdowns. The man power for daily operation shall be under the scope of NIHSAD.
4.	Page no. 14 at Sr. no. 6.10 (b) (Miscellaneous)	The firm will provide proper Ventilation and illumination for complete Gas Bank facility.	The firm shall provide the earthing pit as per requirement and shall provide proper Ventilation and illumination for complete Gas Bank facility.
5.	Page no. 16 at Sr. no. 15(e) (NIHSAD shall provide)	(ii) Electrical supply & earthing pit	(ii) Electrical supply
6	<b>Note: - All the other terms and conditions of the tender shall remain the same.</b>		

  
FOR ADMIN OFFICER