



भाकृअनुप . राष्ट्रीय उच्च सुरक्षा पशुरोग संस्थान
ICAR-National Institute of High Security Animal Diseases
आनंद नगर भोपाल - 46022 म. प्र. भारत
Anand Nagar, Bhopal - 462022 (M.P.), India
Website: www.nihsad.nic.in



F. No. 9-33/22-23/NIHSAD (P&S)

Dated: - 15.09.2022

CORRIGENDUM

The pre-bid meeting with regard to purchase of 40 KVA UPS alongwith accessories vide Tender ID No. 2022_DARE_708232_1 was held on 14.09.2022. As per the Queries raised/discussion in the meeting, the bidders may take into account these points also and submit the bids accordingly:-

Sr no.	Technical Specifications and other terms and conditions mentioned in tender	Now read as
1	Technical Specification : Annexure-VII Clause no.2. a. Power(kwatt)-36kW (PageNo.11)	Power(kwatt)-40kW .
2	Technical Specification : Annexure-VII Clause no.2.d.Battery Backup time minimum 1 hour. (Page no.12)	Battery Back up time minimum 60 min on full load (minimum 60000 VAH)
3	General Design Aspects : Annexure-VII clause no. 2.1.b. Degree of Protection-IP4X (Page no14)	Degree of protection – IP2X or above
4	Annexure-VII:Clause No. 5.a. Installation & Commissioning of the 40 kva online UPS system along with control wiring has to be carried out at the designated location at NIHSAD ,Electrical Substation (Page No. 15.)	Installation & Commissioning of the 40 kva online UPS system along with control wiring (20 mtr approx.) has to be carried out at the designated location at NIHSAD ,Electrical Substation
5	Details of buyback items (UPS& Batteries)	Buyback specifications of UPS (40 KVA, SIEMENS make, model no. UPSB-42) along with 60 Nos batteries (Make-Exide 65Ah,12 VDC)

The bid closing/submission date will be 28.09.2022 5 PM (in place of 21.09.2022 5PM) and accordingly opening date will be 30.09.2022 11:30 AM.


(PS Sunil Kumar)
Administrative Officer