

भाकृअनुप राष्ट्रीय उच्च सुरक्षा पश्रोग संस्थान ICAR-National Institute of High Security Animal Diseases

आनंद नगर भोपाल - 46022 म. प्र. भारत Anand Nagar, Bhopal - 462022 (M.P.), India Website: www.nihsad.nic.in



F. No. 9-33/22-23/NIHSAD (P&S)

Dated: 02.01.2023

NOTICE (For Technical Suitability)

With reference to tender id 2022_DARE_708232_2 for the Purchase of 40 KVA UPS alongwith Batteries on Buy Back Basis (2nd Call) at ICAR Unit, NIHSAD, Bhopal, the technical bids of three under mentioned firms have been found to be technically suitable and the financial bids of the following firms will be opened on 05.01.2023 at 11:00 AM.

Sr. No.	Name of firm	
1.	M/s. Numax Energy Solutions, Hyderabad	
2.	M/s. Prostarm Info Systems Limited, Pune	
3.	M/s. Weartech Engineers Pvt. Ltd., Bhopal	

The offer of following firms are not technically suitable are as follows: -

Sr.	Name of Firm	Reasons
No.		
1.	M/s. Infonpower Systems pvt.	The firm has not submitted the proof
	Ltd., Bangalore	capacity of UPS 40 KW and the firm has
		offered battery backup time minimum
		60 min on full load is 40800 VAH which
		is less than the required battery backup
		time 60 min on full load 60000 VAH.
2.	M/s. Sherin Enterprises, Bhopal	The firm has not filled the tender
		document as per our compliance sheet
		and has not given details of major
		components viz. battery backup, UPS
		dimension etc.

(PS Sunil Kumar) Administrative Officer Phone No. 0755-2750647